



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Central Park Elementary School

43 Oliver Avenue
Pennsville, NJ 08226

Results of Lead Analysis

Date & Time Sampled: 05/20/2017 09:55 - 10:27

Date & Time Analyzed: 05/24/2017 18:50 - 19:56

Date & Time Analyzed: 05/30/2017 17:29 - 17:49


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
CEN-WC-HALL2	<2.00	15.5
CEN-KC-KIT2	5.16	15.5
CEN-KC-KIT1	27.2	15.5
CEN-WC-CAFÉ	<2.00	15.5
CEN-NS-NUR	<2.00	15.5
CEN-SO-LIBOFF	66.6	15.5
CEN-WC-HALL1	<2.00	15.5
CEN-KC-KIT1 (Flushed)	<2.00	15.5
CEN-SO-LIBOFF (Flushed)	189	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date

CENTRAL PARK ELEMENTARY SCHOOL
 43 OLIVER AVE
 PENNSVILLE, NJ 08226

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone 856-875-3506 Fax 856-875-3507
 www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
 Contact: James Eberts
 Address: 1930 Brown Road
 Newfield, NJ 08344
 Phone: _____
 Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	Comp	Lab	No. of Bottles	Pres.	Analysis Requested	Comments
P65838	CEN-FB	5/22/17	0955	D		X	1 x 250		First Draw Lead	FIELD BLANK
P65839	CEN-WC-HALL 2		0958	D		X	1 x 250		First Draw Lead	
P65840	CEN-KC-KIT 2		1000	D		X	1 x 250		First Draw Lead	
P65841	CEN-KC-KIT 1		1000	D		X	1 x 250		First Draw Lead	
P65842	CEN-WC-CAFE		1002	D		X	1 x 250		First Draw Lead	
P65843	CEN-NS-NUR		1005	D		X	1 x 250		First Draw Lead	
P65844	CEN-SU-LIBOFF		1007	D		X	1 x 250		First Draw Lead	
P65845	CEN-WC-HALL 1		1009	D		X	1 x 250		First Draw Lead	
	end of samples			D		X	1 x 250		First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS SISOII SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
X SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	X Standard and Lead Excel NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA format	Preserve upon Receipt Analyze flushed lead/sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L	°C Properly Preserved Yes No

Sampled by: (Print) James Eberts	Date	Time	Received by: (Signature)	Date	Time
Sampled by/Relinquished by: (Signature) James Eberts	5/22/17	1100	[Signature]	5/22/17	1100
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

CENTRAL PARK ELEMENTARY SCHOOL
 43 OLIVER AVE
 PENNSVILLE, NJ 08070

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone 856-875-3506 Fax 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



Customer: Epic Environmental Services, LLC
 Contact: James Eberts
 Address: 1930 Brown Road
 Newfield NJ 08344
 Phone: Fax:
 Office: (856) 205-1077

CHAIN OF CUSTODY RECORD

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	CEN-WC-HALL 2	5/20/17	1025	D	1 x 250		Flushed Lead	
	CEN-KC-KIT 2		1001	D	1 x 250		Flushed Lead	
P66309	CEN-KC-KIT 1		1001	D	1 x 250		Flushed Lead	
	CEN-WC-CAFE		1026	D	1 x 250		Flushed Lead	
	CEN-NS-NUR		1006	D	1 x 250		Flushed Lead	
P66310	CEN-SO-LIBOFF		1008	D	1 x 250		Flushed Lead	
	CEN-WC-HALL 1		1027	D	1 x 250		Flushed Lead	
	End of samples			D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Preserve upon receipt Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L	°C Properly Preserved No

Sampled by:	Date	Time	Received by:	Date	Time
(Print) James Eberts	5/22/17	1100	(Signature)		
Sampled by/Relinquished by:	Date	Time	Received by:	Date	Time
(Signature) James Eberts			(Signature)		
Relinquished by:	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		
Relinquished by:	Date	Time	Received by:	Date	Time
(Signature)			(Signature)		