



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Penn Beach Elementary School

63 Kansas Road
Pennsville, NJ 08226

Results of Lead Analysis

Date & Time Sampled: 05/20/2017 09:19 - 09:48

Date & Time Analyzed: 05/24/2017 23:54 - 01:13

Date & Time Analyzed: 05/30/2017 17:23


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
PBC-WC-APR	<2.00	15.5
PBC-KC-KIT2	47.3	15.5
PBC-KC-KIT1	<2.00	15.5
PBC-WC-HALL2	<2.00	15.5
PBC-TL-FACLG	<2.00	15.5
PBC-NS-NUR	8.97	15.5
PBC-DW-HALL	3.97	15.5
PBC-WC-HALL1	<2.00	15.5
PBC-KC-KIT2 (Flushed)	2.61	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date

CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Fax:
Office: (856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Time		Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
		Date	Time					
P65873	PBC-FB	5/20/17	0919	D	1 x 250		First Draw Lead	FIELD BLANK
P65874	PBC-WC-APR		0922	D	1 x 250		First Draw Lead	
P65875	PBC-KC-KIT2		0923	D	1 x 250		First Draw Lead	
P65876	PBC-KC-KIT1		0924	D	1 x 250		First Draw Lead	
P65877	PBC-WC-HALL2		0925	D	1 x 250		First Draw Lead	
P65878	PBC-TL-FACLG		0926	D	1 x 250		First Draw Lead	
P65879	PBC-NS-NUR		0928	D	1 x 250		First Draw Lead	
P65880	PBC-DW-HALL		0930	D	1 x 250		First Draw Lead	
P65881	PBC-WC-HALL1		0931	D	1 x 250		First Draw Lead	
	end of samples			D	1 x 250		First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER AWAQUEOUS S/SOIL SL/SLUDGE GW/GROUND WATER SW/SURFACE WATER WW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> S-JWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	<i>Preserve upon Receipt</i> Analyze flushed lead/sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L	°C Yes No

Sampled by: (Print) <i>James Eberts</i>	Received by: (Signature) <i>[Signature]</i>	Date 5/23/17	Date 5/23/17	Time 1100	Time Time
Sampled by/Relinquished by: (Signature) <i>James Eberts</i>	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Date	Time	Time

CHAIN OF CUSTODY RECORD

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterest.com
 NJ DEP Certification #08006

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	g d d	g d d	M a t r i x	No. of Bottles	Pres.	Analysis Requested	Comments
	PBC-WC-APR	5/20/17	0946	X		D	1 x 250		Flushed Lead	
P66308	PBC-KC-KIT2		0924	X		D	1 x 250		Flushed Lead	
	PBC-KC-KIT1		0925	X		D	1 x 250		Flushed Lead	
	PBC-WC-HALL2		0947	X		D	1 x 250		Flushed Lead	
	PBC-TL-FACDIN		0927	X		D	1 x 250		Flushed Lead	
	PBC-NS-NUR		0929	X		D	1 x 250		Flushed Lead	
	PBC-DW-HALL		0931	X		D	1 x 250		Flushed Lead	
	PBC-WC-HALL1		0948	X		D	1 x 250		Flushed Lead	
	end of samples			X		D	1 x 250		Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE G: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables P: PWT A Format	Preserve upon Receipt Analyze flushed lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C Yes Properly Preserved No

Sampled by: (Print) James Eberts	Received by: (Signature)	Date 5/22/17 1100	Time 1100
Sampled by/Relinquished by: (Signature) James Eberts	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Received by: (Signature)	Date	Time