



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Valley Park Elementary School

63 Mahoney Road
Pennsville, NJ 08226

Results of Lead Analysis

Date & Time Sampled: 05/20/2017 08:40 - 09:14

Date & Time Analyzed: 05/24/2017 20:03 - 21:03

Date & Time Analyzed: 05/30/2017 17:10 - 17:16


Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
VPK-KC-KIT	12.4	15.5
VPK-WC-HALL2	<2.00	15.5
VPK-SP-LIBOFF	44.9	15.5
VPK-SO-MNOFF	33.7	15.5
VPK-WC-HALL1	<2.00	15.5
VPK-NS-NUR	9.27	15.5
VPK-TL-FACUL	8.75	15.5
VPK-SP-LIBOFF (Flushed)	<2.00	15.5
VPK-SO-MNOFF (Flushed)	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director


Date

CHAIN OF CUSTODY RECORD

Customer:	Epic Environmental Services, LLC
Contact	James Eberts
Address:	1930 Brown Road Newfield, NJ 08344
Phone:	Fax:
Office:	(856) 205-1077

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwaterest.com
 NJ DEP Certification #08006



Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
P65846	VPK-FB	5/20/17	0840	D	1 x 250		First Draw Lead	FIELD BLANK
P65847	VPK-KC-KIT		0845	D	1 x 250		First Draw Lead	
P65848	VPK-WC-HALL 2		0847	D	1 x 250		First Draw Lead	
P65849	VPK-SO-LIBOFF		0850	D	1 x 250		First Draw Lead	
P65850	VPK-SO-MNOFF		0852	D	1 x 250		First Draw Lead	
P65851	VPK-WC-HALL 1		0853	D	1 x 250		First Draw Lead	
P65852	VPK-NS-NUR		0854	D	1 x 250		First Draw Lead	
P65853	VPK-TL-FACUL		0856	D	1 x 250		First Draw Lead	
	end of samples			D	1 x 250		First Draw Lead	

MATRIX ABBREVIATIONS: DIDRINKING WATER A/AQUEOUS S/SOIL SL/SLUDGE GW/GROUND WATER SWS/SURFACE WATER WWW/WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> SJWT Standard is 10-20 work days <input type="checkbox"/> Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel <input type="checkbox"/> NJ DEP Reduced Deliverables <input type="checkbox"/> NJ DEP Full Deliverables <input type="checkbox"/> Electronic Data Deliverables <input type="checkbox"/> PWTA Format	Preserve upon Receipt Analyze flushed lead/sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L	°C Properly Preserved Yes No

Sampled by: (Print) James Eberts	Date 5/22/17	Time 1100	Received by: (Signature) [Signature]	Date 5-22-17	Time 1100
Sampled by/Relinquished by: (Signature) James Eberts	Date	Time	Received by: (Signature)	Date	Time
Relinquished by: (Signature)	Date	Time	Received by: (Signature)	Date	Time

VALLEY PARK ELEMENTARY SCHOOL
 63 MAHONEY RD
 PENNSVILLE, NJ 08070

South Jersey Water Test, LLC
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 Phone: 856-875-3506 Fax: 856-875-3507
www.sjwatertest.com
 NJ DEP Certification #08006



CHAIN OF CUSTODY RECORD

Customer: Epic Environmental Services, LLC
Contact: James Eberts
Address: 1930 Brown Road
 Newfield, NJ 08344
Phone:
Office: Fax: (856) 205-1077

Lab ID#	Sample Location	Collection Date	Time	Matrix	No. of Bottles	Pres.	Analysis Requested	Comments
	VPK-KC-KIT	5/20/17	0846	D	1 x 250		Flushed Lead	
	VPK-WC-HALLZ		0913	D	1 x 250		Flushed Lead	
966306	VPK-SO-LIBOFF		0851	D	1 x 250		Flushed Lead	
966307	VPK-SO-MNOFF		0853	D	1 x 250		Flushed Lead	
	VPK-WC-HALL1		0914	D	1 x 250		Flushed Lead	
	VPK-NS-NUR		0855	D	1 x 250		Flushed Lead	
	VPK-TL-FACUL		0857	D	1 x 250		Flushed Lead	
	end of samples			D	1 x 250		Flushed Lead	
				D	1 x 250		Flushed Lead	

MATRIX ABBREVIATIONS: D: DRINKING WATER A: AQUEOUS S: SOIL SL: SLUDGE GW: GROUND WATER SW: SURFACE WATER WW: WASTE WATER

Turnaround Time	Report Format	Comments/Special Instructions	Cooler Temp
<input checked="" type="checkbox"/> S.JWT Standard is 10-20 work days Rush turnaround available upon request and lab approval _____	<input checked="" type="checkbox"/> Standard and Lead Excel NJ DEP Reduced Deliverables NJ DEP Full Deliverables Electronic Data Deliverables PWTA Format	<u>Preserve upon Receipt</u> Analyze flushed/lead sample for any sample location in which the first draw lead result exceeds the action limit of 15.5 ug/L.	°C Properly Preserved Yes No

Sampled by: (Print) James Eberts	Date	Received by:	Date	Time
(Signature) <i>James Eberts</i>	5/22/17	(Signature)		
Relinquished by:	Date	Received by:	Date	Time
(Signature)		(Signature)		
Relinquished by:	Date	Received by:	Date	Time
(Signature)		(Signature)		